DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:____

DATE: 6-5-95

COUNTY: Iredell

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Randy Garwood
OWNER___AGENT:___PHONE:____
ADDRESS:____
APPLICATION DATE:____ DATE EVALUATED 6-5-95
PROPOSED FACILITY:____
PROPERTY SIZE:____
LOCATION OF SITE: Corner of Slatepark Rd and Lockhard Rd.
WATER SUPPLY: On-site Well ✓ Comm. Well___Public___Other____ EVAL. METHOD: Auger Boring ✓ Pit___Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	4-6%	0-5"	l	gr	1:1 / fr			.1942 Wetness Cond. - S
	L	5"-48"	c	wsbk	1:1 / f			.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - NA
								.1948 Profile Class. - P.S
								Profile LTAR - .3
2	4-6%	0-4"	l	gr	1:1 / fr			.1942 Wetness Cond. - S
	L	40"-30"	c	wsbk	1:1 / f			.1943 Depth/.1956 Sapr. - NA
		30"-48"	c/sap.	wsbk/m	1:1 / f			.1944 Restrictive Hori. - NA
								.1948 Profile Class. - P.S
								Profile LTAR - .3
3	4-6%	0-4"	l	gr	1:1 / fr			.1942 Wetness Cond. - S
	L	4"-15"	c	wsbk	1:1 / f	relic mottling		.1943 Depth/.1956 Sapr. - NA
		15"-48"	c	wsbk	1:1 / f			.1944 Restrictive Hori. - NA
6-28-95								.1948 Profile Class. - P.S
								Profile LTAR - .3
4	4-6%	0-3"	l	gr	1:1 / fr			.1942 Wetness Cond. - S
	L	3"-17"	c	wsbk	1:1 / f	relic mottling		.1943 Depth/.1956 Sapr. - NA
		17"-48"	c	sbk	1:1 / f			.1944 Restrictive Hori. - NA
6-28-95								.1948 Profile Class. - P.S
								Profile LTAR - .3

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946)____ SITECLASSIFICATION (.1948) P.S.

SYSTEM TYPE conventional gravity fill LONG-TERMACCEPTANCE RATE(S) .3gpd/ft²

EVALUATED BY: Michael J. Dennis OTHER(S) PRESENT:____

COMMENTS:____