Pete Belk.
Bldr

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jimmy Kausch DATE 1/25/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd. at Troutman. T.R. on State Park Rd. T.L. at #1322 (Romac Metals) House on Rt. Near End of Road. S. R. No. 1322


SUBDIVISION NAME Allison Acres #2 LOT NO. 4 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prov. Suitable (Poor)
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 20,000 Sq ft



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Orbison

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water possible to be diverted away from Tank + Lines.
Installed in wet weather

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 1/25/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold