06801

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ROMAC METALS DATE 10-21-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Park Grove Rd. from Troutman 2-T.R. on State Park Rd-T.L. on Honeycutt Rd.- ½ mi. on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 20 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other Addition of 150'x165' manufacturing bldg.

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. W.sh. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Lot Area Ample

Character & Porosity of Soils Prev. Suitable.


Percolation Rate 2 gal/sq.ft.

Topography 2-6%

Depth to Water Table 10+

Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Lineal Ft. 330
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Detwalt

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Do not park or drive over S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-21-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold