# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14512 PIN# 473035 8488 DATE 9/24/07

OWNER OR APPLICANT NEW AMERICAN BUILDERS PHONE: Business 704-201-8855 Home

ADDRESS PO BOX 567 WAXHAW NC 28173

LOCATION PERTH RD (R) STATE PARK (L) RUSHING WATER BY Creek on LEFT

SUBDIVISION TWIN CREEKS BLOCK / SECTION LOT 7 LOT AREA 21153 SITE CLASS. PS DESIGN FLOW 420 L.T.A.R. 13

Septic Tank: 1000 Gallons; STB 794 Date 10-13-07

Pump Tank: 1000 Gallons; PT 34 Date 11-3-07

Pump Make: ZOELLNE Model E-165-C Serial No.

Nitrification Field: No Fields 1 Square Feet 420=1600 Linear Feet 400'

No Lines 5X80 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: PUMP 35% REDUCT

Repair System Description: SAME

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 6 No. Employees

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Supply Line put in by developer BY Permit Was ISSUED. PUT IN FILE

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM PLAN BY LORNE COOK, R.S.

Comments/Conditions: X VID TANKS ON TANK TRUCK ONLY X PLAYLOK FILTER + MARKER PUMP TANKS ON 2/23/08 WPM RISER Installed

AS BUILT SKETCH

The proposed 33'x18' POOL addition does not appear to impact the existing septic system.

**NOTE: POOL IS 15' + FROM TANKS & DECKS ARE 5' + FROM TANKS

R.S.

Date: 4-24-08

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with ~~plat~~ valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9/25

Improvement Permit by: date 9/24/07

Authorization to Construct by: date 9/24/07

Installed by: Commercial Services

Operation Permit by: date 2-8-08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK