5 1/2 TETHER
NEED # OF PAGES

# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14347 PIN# 4730-45-7392 4730-36-5152 DATE 5-21-07

OWNER OR APPLICANT Summerwood Homes PHONE: Business 704 507-1245 Home

ADDRESS 173 WEST MAGNOLIA RD MOORESVILLE, NC 28117

LOCATION 21 SOUTH (R) Perth (R) Stake Deck (L) [redacted] Rushing WATER on Rt BU Creek

SUBDIVISION Twin Creeks BLOCK / SECTION LOT 16 LOT AREA 1.57+/- 1.45AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 1217 Date 5-4-07

Pump Tank: 1000 Gallons: PT 17 Date 4-4-07

Pump Make: Billco Model WEBB Serial No. LD775465

Nitrification Field: No Fields 1 Square Feet 1600' Linear Feet 270'

No Lines 2 split Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LOW Pressure 50%

Repair System Description: SAME

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: (1) See OFFSITE PLANS That ARE ATTACHED

Comments:/Conditions: TUFFTEK F. the IMPACT

INITIAL SITE SKETCH

SEE ATTACHED OFFSITE PLAN DESIGNED BY LORUE COOK R.S.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 5-21-07 Installed by: STEVE JORDAN

Improvement Permit by: [signature] date 5-21-07 Operation Permit by: [signature] date 12-19-07

Authorization to Construct by: [signature] date 5-21-07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK