IREDELL COUNTY HEALTH DEPARTMENT

This permit voids #119374 issued 7-20-2004

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

(U)

PERMIT# 142787 PIN# 4730-40-2169 DATE 6-11-07

OWNER OR APPLICANT HEATH CAMPBELL PHONE: Business 704-838-8934 Home 704-641-1000 cell

ADDRESS 3450 CAMBRIDGE PLACE STATESVILLE NC 28625

LOCATION STATE PARK ROAD TO HONEYCUTT, TR BEE FOX, TL CAPTAINS [illegible], TR ANCHOR LANE, LOT AT END ON LEFT

SUBDIVISION CAPTAIN'S COVE BLOCK / SECTION ____ LOT 10 LOT AREA 0.589 ACRE SITE CLASS PS DESIGN FLOW 360' L.T.A.R. 0.25 GPD/FT²

Septic Tank: 1000 Gallons; STB 760 Date 8-18-07

Pump Tank: 1000 Gallons; PT 363 Date 10-1-07

Pump Make: ZOELLER Model 154-BN Serial No. ____

Nitrification Field: No Fields 1 Square Feet EQ. 1440 Linear Feet 240

No Lines THREE Trench Width 24" Max Trench Bottom Depth 36" SAND Depth 24"

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 50% REDUCTION, LOW-PRESS

Repair System Description: 50% REDUCTION, LOW-PRESS

Maintenance Agreement Required: ☑ Yes ☐ No

☐ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons ____ No. Employees ____

Water Supply: ☑ Individual ☐ Public ☐ Community WELL off SIT

☐ Gravity ☑ Pressure ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: ① INSTALL 50% REDUCTION SYSTEM ON CONTOUR AS SHOWN USING LOW-PRESSURE DISTRIBUTION ② KEEP SYSTEM MINIMUM 50 FEET FROM WELL (LOCATED OFF SITE) ③ A CONTRACT SHALL BE EXECUTED BETWEEN SYSTEM OWNER & MANAGEMENT ENTITY PRIOR TO ISSUANCE OF O.P.

Comments/Conditions: DWG LOW F. Ht & PTSOIS TANKS MEASURED 50' TO 760 HIGH WATER MARK.

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN PREPARED BY MICHAEL ATHANAS & ASSOCIATES, INC.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 6/12/07

Improvement Permit by: STEVE HENDRICK date 6-11-07

Authorization to Construct by: STEVE HENDRICK date 6-12-07

Installed by: SAMMY REAVIS

Operation Permit by: STEVE HENDRICK date 12-21-07

Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK