IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Franklin Mayberry DATE 12/12/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Beth Rd at Troutman. T.R. on 1321 - T.L. at Romac Metals on Rd # 1322. T.L. in Sub Div. House on Rt. S. R. No. _____

SUBDIVISION NAME Tremont LOT NO. 10-11 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 5 Acres

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slope to back Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Divert Surface water away from Septic Tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/12/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold