IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 CI= MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 144364 PIN# 4730452972 DATE 8-31-07

OWNER OR APPLICANT NEW AMERICAN BUILDERS PHONE: Business 704-201-8855 Home

ADDRESS PO BOX 567 WARSAW NC 28173

LOCATION PERTH RD (R) State Park (L) Twin Creeks Drive on RT LOT # 57

SUBDIVISION TWIN CREEK BLOCK / SECTION LOT 57 LOT AREA 1.23 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. 125

Septic Tank 1000 Gallons; STB 744 Date 12/21/07

Pump Tank: 1000 Gallons; PT 27 Date 12/21/07

Pump Make: ZOELLER Model N-152 Serial No.

Nitrification Field No Fields 1 Square Feet 660=1920 Linear Feet 320'

No Lines 4x80' Trench Width 24" Max Trench Bottom Depth 24" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LOW PRESS NON PROJECT

Repair System Description: SAME

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons 8

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments./Conditions ① Kup House Out of Ground & BACKFILL for the 10' Positive Drainage REQMTS. Septic Lines CAN THEN BE 5' OFF DRAINAGE, 15' OFF HOUSE AS DRAWN, EXPANDED & MET WITH BUILDER

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY JORNE COOK, R.S.

Comments./Conditions ② CALL Perk for installation for Pump Sizing & System Specs if necessary ③ House & System Completely Flagged OUT. House SLID BACK 20' from Original Staking. Drawn Correctly on Permit. BUILDER OK'D

AS BUILT SKETCH SLID BACK 20'.

POLYLOK FILL & MOUND

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 8/31/07 Installed by: Commercial Services

Improvement Permit by: [signature] date 8/31/07 Operation Permit by: [signature] date 2-21-08

Authorization to Construct by: [signature] date 8/31/07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK