C1

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140132 PIN# 4730-45-6829 DATE 7-13-07

OWNER OR APPLICANT S+L Homes PHONE: Business 704 663-8467 Home 704-622-7499

ADDRESS 110 CHARLESTON DR SUITE 107 MOORESVILLE NC 28117

LOCATION 21 SOUTH (R) Perth (R) State Rd (L) TWIN CREEKS LOT #1 LEFT AFTER CROSSING CREEK

SUBDIVISION TWIN CREEKS BLOCK / SECTION II LOT 51 LOT AREA 1.66 SITE CLASS. PS DESIGN FLOW 482 L.T.A.R. 1.5

Septic Tank: 1000 Gallons; STB 1000 Date 3-19-07

Pump Tank: 1000 Gallons; PT 1274 Date 4-16-07

Pump Make: ZOELLER Model N-157 Serial No.

Nitrification Field: No Fields 1 Square Feet EQ=1600 Linear Feet 280'

No Lines 4470' Trench Width 24" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP SD'L REDUCTION

Repair System Description: SAME

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☐ Individual ☒ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: ① This Permit WAS ISSUED BECAUSE ORIGINAL Comments Were not followed ABOUT Positive Pressure REPAIRS, LOT REPAIRS Were NOT [redacted] Filled As Specified BUT Graded. Initial System IS STILL the same but Repair Area HAD TO BE CHANGED.

INITIAL SITE SKETCH

AS BUILT SKETCH

* SEE ATTACHED PERMIT DESIGN FOR Initial System SUBMITTED BY ROLLANES SOIL & ENVIRONMENTAL "FAST TRACK" SUBMITTAL.

* NEW REPAIR DESIGN BY LOWE COOK, R.S.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Mark Lay date 7-13-07

Improvement Permit by: [signature] date 7-13-07

Authorization to Construct by: [signature] date 7-13-07

Installed by: Wayne Clontz

Operation Permit by: [signature] R.S. date 17 Aug 07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

NEW PERMIT
140132
4730456829

