C1

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140132 PIN# 4730-45-6829 DATE 7-13-07

OWNER OR APPLICANT S&L Homes PHONE: Business 704 663-8467 Home 704-622-7499

ADDRESS 110 CHARLESTON DR SUITE 102 MOORESVILLE NC 28117

LOCATION 21 SOUTH (R) Perth (L) State Rd (L) TWIN CREEKS LOT NO 1 OFF AFTER WE CROSS CREEK

SUBDIVISION TWIN CREEKS BLOCK / SECTION # LOT 51 LOT AREA 1.66 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. 1.5

Septic Tank: 1000 Gallons: STB 1000 Date 3-19-07
Pump Tank: 1000 Gallons; PT 374 Date 4-16-07
Pump Make: ZOELLER Model N-157 Serial No.
Nitrification Field: No Fields 1 Square Feet EQ=1600 Linear Feet 280'
No Lines 4X70' Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LPSD: REDUCTION
Repair System Description: SAME
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons 12
☐ Business No. Employees
☐ Other

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: (1) This Permit WAS ISSUED BECAUSE ORIGINAL Comments WERE not follow'd ABOUT Positive Pressure REPORTS. LOT REPORTS WERE NOT [redacted] Filed As Spelled BUT

Comments/Conditions: Graded. Initial System IS STILL the same but Repair Area HAS TO BE CHANGED.

INITIAL SITE SKETCH

AS BUILT SKETCH

* SEE ATTACHED PERMIT DESIGN FOR INITIAL System SUBMITTED BY ROWANES SOIL & ENVIRONMENTAL "FAST TRACK" SUBMITTAL.

* NEW REPAIR DESIGN BY LOWE COOK, R.S.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Mark Lay date 7-13-07
Improvement Permit by: [signature] date 7-13-07
Authorization to Construct by: [signature] date 7-13-07

Installed by: Wayne Clontz
Operation Permit by: [signature] R.S. date 17 August 07
Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK