THIS PERMIT REPLACES PREVIOUSLY ISSUED PERMIT DATED 8-31-06

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (CI) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 136352 PIN# 4730465069 DATE 10-11-06

OWNER OR APPLICANT SUMMERWOOD HOMES PHONE: Business 704-799-8085 Home

ADDRESS 173 WEST MACINTA RD MOORESVILLE NC 28117

LOCATION STATE RD 1625 (L) TWIN CREEKS ON LEFT ON CORNER OF WINDING CREEK

SUBDIVISION TWIN CREEKS BLOCK / SECTION LOT 50 LOT AREA 1.03 AC SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 1012 Date 10-20-06

Pump Tank: 1000 Gallons; PT 11 Date 8-12-07

Pump Make: Gould's Model WE30M1 Serial No. 6HB0156B4

Nitrification Field: No Fields 1 Square Feet ED=1440 Linear Feet 240'

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V

System Description: LOW PRESSURE 50% REDUCT

Repair System Description:

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons 6

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☒ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Comments:/Conditions:

1) RUN SURFACE WATER DIVERSION DOWN P/L
2) MEET HEALTH DEPT BEFORE POSITIVE DRAINAGE OUTLETS MADE. IF NOT PERMIT COULD BE VOIDED
3) INSTALL LINES ON CONTOURS & MAINTAIN SETBACKS;

INITIAL SITE SKETCH

1"=30'

AS BUILT SKETCH

4) CALL PRIOR TO INSTALLER TO PUMP SIZING & SYSTEM SPECS IF NECESSARY
5) SEPTIC LINES ARE 8' OFF HOME AS STAKED, BUILDER MET & CONFIRMED THIS IS ENOUGH ROOM FOR SIDE WALK & PLANTERS.
6) SYSTEM IS STAKED OUT FOR SCALE, ANY CHANGES WILL VOID PERMIT
7) DO NOT CUT DITCH THRU REPAIR AREA

Syfone filter
Yellow tag-tile
Riser on pump tank
Risers on septic tank to ground

Permit can be suspended or revoked if any false information is supplied toward securing the permit, any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date

Improvement Permit by: [signature] date 10-11-06

Authorization to Construct by: [signature] date 10-11-06

Installed by: Steve Jordan

Operation Permit by: [signature] date 6-7-7

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK