Monitoring Report Form
Subsurface Wastewater Disposal System

System Manager:

Gary W. Simmons
Extreme Wastewater Management
P.O. Box 743
Newton, NC 28658
828-217-7749

System Owner:

Paul DeRatier
127 Winding Creek Drive
Troutman, NC 28166
Twin Creek Estates Lot # 28

Date of Inspection:
4-8-08

System Classification & Type: 4A Pump/Panel

Septic Tank

Tank risers accessible?	NO ACCESS RISER
Signs of infiltration?	N/A
Tanks and access structurally sound?	N/A
Sanitary tee in good condition?	N/A
Effluent filter cleaned?	NO ACCESS
Effluent filter in good condition?	N/A

Pump Tank

Signs of infiltration?	NO
Tank riser height?	YES
Required pumps present, operating, and cycling properly?	YES
Effluent appears clear, free of excess solids?	YES
Floats, pipes, valves, and disconnects in good condition?	YES
High water alarm present and operating properly?	YES TESTED 4-8-08
Control panel and components in good condition?	YES

Drain Field

Evidence of effluent surfacing?	NO
Surface water being effectively diverted away?	YES
Line cover & vegetative cover maintained properly?	YES
Protected from traffic, destructive uses?	YES
Turnups, cleanouts, and valves intact and accessible?	YES
Laterals free of excess solids, cleaned out as needed?	YES FLUSHED 4-8-08
Pressure head is properly adjusted?	YES ADJUSTED 4-8-08 FILTER CLEANED 4-8-08

Summary of improvements needed:

Signed: Gary W. Simmons
SSWW Certified Operator # 986953

CONTRACT RENEWAL

I, Paul J. DeRatier, choose to renew my contract with Gary W. Simmons of Xtreme Wastewater Management to be the Certified Operator of my septic system. I understand that by signing this renewal form that the terms of the original contract will remain as they were.

The cost of this contract is $200.00 per year.

Signed _____ Date 3/14/08

Paul J. DeRatier
127 Winding Creek Drive
Troutman, NC 28166

Twin Creek Subd. Lot # 28