IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Pipes DATE 10-12-73 PERMIT NO. _____

PHONE Business _____ Home 528-6569

LOCATION Hwy 21 S - T.R. at Troutman on Perth Rd # 1303 - T.R. on State Park Rd # 1321. ½ Mile - Metal Bldg on L S. R. No. 1321

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other _____

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Red Clay


Percolation Rate Mt Park Test Made.

Topography Level.

Depth to Water Table Low

Rock or other impervious formations None

Lot Area 1.07 Acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Alexander Septic Tank Co.

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: Water from well at house. Bldg. to be used for Community Grocery.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 10/15/73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold