TOWN OF TROUTMAN.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR: JAMES BROUWER DATE: 10-1-90 PERMIT NO. 344M1.

PHONE: Business _____ Home _____

LOCATION: Nat. Park Rd. off Post Church Rd. - go approx. ¾ mi. on left. S. R. No. _____

SUBDIVISION NAME: PINECRAFT DEV. LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soils: Fair suitable.

Percolation Rate: 3-30 M.P.I.


Topography: Rolling

Depth to Water Table: 12+

Rock or other impervious formations: Rock observed.

Lot Area: Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank: 1000 Gals.

Nitrification Field:

No. of Lines: 2

Sq. Ft.: 300 Linear Ft.: 300

Depth of Stone in Lines: 12"

Water Supply: Individual (✓)

Public ( )

Installed by: James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY: Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY: Steve Brown DATE: 5-1-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

Location of the proposed ATTACHED GARAGE addition does not appear to impact the existing on-site septic system.**NOTE: NO PLUMBING

R. STEVE HEDRICK REHS

Date: 9-22-2011

ICHD-Environmental Health Division

Location of the proposed