DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4730-48-6343(PT)

OWNER: C & S ASSOCIATES, LLC APPLICANT: GINGER CECIL
ADDRESS: 904 SALEM ST. THOMASVILLE APPLICATION DATE: 8-18-99 DATE EVALUATED: ___
PROPOSED FACILITY: 3BR H W/CS PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 15,000 SF
LOCATION OF SITE: MEADOW GLEN #17 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	PIT L 4%	0-2	ORGANIC/ LITTER						PS 0.25
		2-6	WCGR / PRIMARILY L	FR / NEXP					
		6-12	WMSBK / CL	FR-S / NEXP					
		12-48	MMSBK / C	FI SS/P / NEXP					
2	L 6%	0-6	GR / L	FR / NEXP					PS 0.25
		6-10	WMSBK / CL	FR S / NEXP					
		10-48	MM ABK MMSBK / MICACEOUS C-	FI SS/P / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: ___