4730508550

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. W. Hon Est DATE 6-29-76 PERMIT NO. 471

PHONE: Business _____ Home _____

LOCATION 303 N. Elon 1405 T Ave 1160 W 5th

Left on Left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 155 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area _____


Character & Porosity of Soil Sandy Clay loam Porous

Percolation Rate 1" in 10 min

Topography Fair to good slope

Depth to Water Table 10-12

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 125 Linear Ft. 500

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public ( )

well Well 4" bore

Installed by Henry Stevens

Rec'd 53.00

IMPROVEMENTS PERMIT BY J. E. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Shuford DATE 6-29-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold