IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR WAYMOUTH MOORE DATE 4-2-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION State Park Rd. - 7th Pettit Ch. Rd., go to 1st landtop on left (Pomac Rd.) then to 1st landtop on left, go to end, T.R. - 2nd house on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes ✓ No ( )

Lot Area Approx. 20000 sq ft.

Character & Porosity of Soil Cecil clay


Percolation Rate .5 gal/sq ft.

Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations None

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field: 3

No. of Lines _____

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by Eddie Yountz

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: If swimming pool is installed, keep it at least 20' from the septic tank system. Do not pave over the septic tank and lines.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-2-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold