IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TONY ELLIOTT DATE 10-31-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION State Park Rd. off Perth Church Rd. - T.L. on Honeycutt Rd. - then T.L. on Tremont Dr. - house on left at STOP SIGN. S. R. No. _____

SUBDIVISION NAME TREMONT SUBD. LOT NO. 21 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Spray Suitable.
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Sat. 1 sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none observed.

Lot Area 2.12 acres

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 10-31-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold