IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gray Harris DATE 2/22/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Juct on Perth Rd at Troutman T.R. on Rd #1321 - T.L. on Rd 1322. He approx ½ mile T.L. into sub division S. R. No. _____

SUBDIVISION NAME Dremount LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 30,000 Sq ft +


Character & Porosity of Soil Prov Suitable

Percolation Rate _____

Topography Slope to Lake

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 747 Linear Ft. 320
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Osteen

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts and all surface water possible should be diverted away from Septic Tank + lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 2/22/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold