IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JOHN COOK DATE 6-29-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Perth Church Rd. - 1/2 mile past State Park Rd. T.R. into Dev. - house at end of in woods. S. R. No. _____

SUBDIVISION NAME Perthwood Estates LOT NO. 21 & 22 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	✓	No	( )
Auto. Dishwasher	Yes	✓	No	( )
Auto. Wash. Machine	Yes	✓	No	( )
Site Suitable	Yes	✓	No	( )

Character & Porosity of Soil clay fine sandy loam
Percolation Rate 16 gal/sq. ft
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

Lot Area 2.20 acres

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by John Cook

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe off downspouts from gutters so they don't empty onto septic tank system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-29-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold