1904.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JEFF KELLY DATE 11-16-90 PERMIT NO 3F-8-A-20.

PHONE: Business _____ Home _____

LOCATION Set Rt. 2 just off Rt. 3 on Jourdan 2 go past State Park Rd. 1st R into last road to 1st left to lot.


SUBDIVISION NAME PERKINWOOD ESTATES. LOT NO. 20. SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev. Suitable.	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	3 Min/Inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Flat	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	84"	
Lot Area Ample.			Rock or other impervious formations	None Observed.	

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 330 Lineal Ft. 310
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Braun

COMMENTS: Sewage grinder pump installed in basement floor for basement plumbing.

CERTIFICATE OF COMPLETION BY Steve Braun DATE 11-26-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold