36479

TOWN OF TROUTMAN.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR PAUL C. WAGNER DATE 7-3-90 PERMIT NO. 3H-D-L

PHONE: Business _____ Home _____

LOCATION Rt 10 Off Jerusalem Church Rd. to T.R. on State Rd. go ¼ mile T.L. into

SUBDIVISION NAME PINECREST II LOT NO. 3 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5 Character & Porosity of Soil Poor Suitable

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate _____ Min/In.

Auto. Dishwasher Yes (✓) No ( ) Topography _____

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table _____

Site Suitable Yes (✓) No ( ) Rock or other impervious formations Rock Observed.

Lot Area 1.389 acres


_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1250 Gals.

Nitrification Field: No. of Lines 3 Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓) Public ( )



Plot of System

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown & Steve Hedrick DATE 7-3-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold