TOWN OF TROUTMAN. Kiesling, Alfred 41300

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CRAIG M. ROSEMAN DATE 1-8-92 PERMIT NO. 3H-4-A-10.

PHONE: Business ~~0~~ Home

LOCATION State Park Rd. off Perth Church Rd. - 1/4 mi. on left. - corner lot to entrance of dev.


SUBDIVISION NAME PINECROFT DEV. LOT NO. 10. SECTION OR BLOCK NO. S. R. No.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Gravy Suitable.
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate 4 min./1 in.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2 - 15%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'+
Lot Area Ample.			Rock or other impervious formations none observed.

Basement with Plumbing ___ Basement without Plumbing ___ No Basement ✓



Size of Tank 1000 Gals.
Nitrification Field: 4
No. of Lines
Sq. Ft. 900+ Linear Ft. 300+
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Little Hawkins

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 1-8-92.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold