TOWN OF TROUTMAN.

Rebuild Wagner ea Abandoned

38633

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LARRY D. GRADY DATE 3-27-91. PERMIT NO. 3H-D-1.

PHONE: Business _____ Home _____

LOCATION Bethel Church Rd. from Troutman -T.R. on State Park Rd. -T.L. on 1st paved st. -go around curve, on left. S. R. No. _____

SUBDIVISION NAME PINECROFT DEV. LOT NO. 6. SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2.

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Gray Suitable.
Percolation Rate 4 gal/sq. ft.
Topography 2-6%
Depth to Water Table 10'
Rock or other impervious formations none observed.

Lot Area .459 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Liner Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Wes Lytton.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Keep well at least 50' from S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-27-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold