SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: _____ APPLICANT: _____
DRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12/3-00
POSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
ATION OF SITE: 64 MB ybc of Waterboro PROPERTY RECORDED: _____
TER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
LUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
E OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-5	gr wk sabbw sl/gl fr						
	5-24	SAB rc/l	fr					
	24-58	wk/sab/gr yc cl/L	fi ss p/sp	fav-common/sp				
	0-3	gr brn sl/sl cl						PS .3
	3-18	SAB rc/cl	fr					
	18-36	wk/sab/gr yc cl/L	common/sp	fi fr ss p				
	36-62	L/SL sap	fr ss p					
	0-4	brn sl/cl L						PS .3
	4-22	SAB rc/cl	fr					
	22-32	wk/sab/gr yc	cl	fav-common/sp	fi fr ss p			
	32-64	massive yc L sap	fri/clay	fi-fr ss p				
AH 3-14-01	0-4	wk sab brn sl	fr ss p					PS .3
	4-32	SAB rc/l	fr ss p/sp					
	32-51	wk/sab/gr yc cl/L	common-many/sp	fav-com/sp				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
able Space (.1945)		
m Type(s)		
.TAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____