

MICHAEL ATHANAS & ASSOCIATES, INC.
LICENSED SOIL SCIENTIST
1999 CANDLEWICK DRIVE
FORT MILL, S.C. 29715
803-802-4403 (office)
803-802-4402 (fax)

Reference: Data Sheet for Winding Forest Lot 43
House Footprint: 60' x 70'
Building Setback: 35' front/back, 15' side
Water Source: Community Well
Number of Bedrooms: 4/480gpd
Proposed LTAR: 0.3 gpd/ft2
Suggested system type: 25% reduction
Distribution: Gravity-Drop Boxes
Septic tank size: 1000 gallons
Proposed Trench Bottom: 36"

Line	Length
White 1	55'
Orange 2	140'
Red 3	130'
Blue 4	80'

Initial system: 405'

Comments: The repair area was previously determined by Iredell County to be low pressure PPBPS. The house location and the repair area did not change from the original permit.