~~4730707787~~ 4730605857

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tony Lee Black DATE 9-28-79 PERMIT NO. 333

PHONE: Business _____ Home _____

LOCATION 1303N TL. on 1439 .5 mi on left

S. R. No. _____


SUBDIVISION NAME Shady Cove LOT NO. 33, 34 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 mpi	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.	
			Rock or other impervious formations	none obs.	

Lot Area 1 AC.



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Robert Hoke

IMPROVEMENTS PERMIT BY H. R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R Henson DATE 9-28-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold