4730 60 7055

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 129537 PIN# 4730 70 5378 .021 DATE 10/11/06

OWNER OR APPLICANT Bo of NC dba HERITAGE HOMES PHONE: Business 704-489-4663 Home

ADDRESS 5734 Hwy 16 South Denver, NC. 28037

LOCATION North N TL Winding Forest on (R) near cul de sac

SUBDIVISION Winding Forest BLOCK / SECTION LOT 21 LOT AREA .659 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 350 Date 10/26/06 ok

Pump Tank: 1000 Gallons; PT 318 Date 11/1/06 ok

Pump Make: Little Giant Model 14EN Serial No.

Nitrification Field: No Fields 1 Square Feet 640 Linear Feet 320

No Lines 4 Trench Width 2' Max Trench Bottom Depth 32"-34" Gravel Depth No

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 16" APBPS – LP

Repair System Description: SAME

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☐ Public ☒ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: See Attached Site Plan, System Design, and Specifications Sheet by ROLLINS SOIL + ENVIRONMENTAL SERVICES.

Comments:/Conditions: 3 lines

INITIAL SITE SKETCH

(1) Copies of Site Plan + Specifications available from I.C.H.D.

(2) No changes allowed without approval from I.C.H.D.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: * Duane Lovelace date 10-13-06 Installed by: Piedmont Septic Tank

Improvement Permit by: Wesley Sparks RS date 10/11/06 Operation Permit by: Wesley Sparks R.S. date 6/4/08

Authorization to Construct by: Wesley Sparks R.S. date 12/7/06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK