(Wells must be abandoned GW-30 x2)

4730-60-9064

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 129539 PIN# 4730 70 5378 704-696-2662 DATE 7/21/06

OWNER OR APPLICANT BO of NC/HERITAGE HOMES PHONE: Business 704-489-4663 Home

ADDRESS 5734 Hwy 150 East Denver, NC. 28037 249 Williamson Rd.

LOCATION 150 W TR Poth Rd. TL Windy Forest 1st on R

SUBDIVISION Windy Forest BLOCK / SECTION LOT 22 LOT AREA .683 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 794 Date 12/22/09
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480
No Lines 6 Trench Width 3' Max Trench Bottom Depth 36+ Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: DROP BOX - 25% REDUCED.
Repair System Description: Pressure - 16' PPBPS
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☐ Public ☒ Community

☐ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: FAST TRACK; ROLLANS ENVIRONMENTAL ACCEPTABLE FOR GRAVITY 25% REDUCTION SYSTEM LOCATION AS SHOWN ON SITE PLAN & DRAINFIELD AREA SHEET.

Comments/Conditions:
- REDRAW 10/24/06 - JE
- Moved house to fit in 3 car garage
- Tank shifted to side of house

INITIAL SITE SKETCH

ROLLANS ENVIRONMENTAL

PLANS & SPECS REQUIRED BEFORE INSTALLATION STARTED.

House Plan Review Required!

AS BUILT SKETCH

6+8 6-9.5
7-8 7-9
8-5 9-5
8-10 8-10
9-8 9-8
10- 10-

ABANDON BOTH WELLS - TOO CLOSE TO REPAIR AREA

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Duane Laughlaw date 7-24-06 Installed by: Piedmont Septic Tank

Improvement Permit by: Wesley Sparks RS date 7/21/06 Operation Permit by: Wesley Sparks RS date 5/29/08

Authorization to Construct by: Joseph E. Allen date 10/24/06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK