HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____ ____
PROPERTY RECORDED: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Clyde Hall Baker, Inc. OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 8-16-94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Parkwood S/D Lot # 13
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	3-5% L	0-4"	cl	gr	vfr	.1942 WETNES CONDITION - S
		4"-36"	c	sbk	fi	.1943/.1956 SAPROLITE - 36" P.S.
		36"-48"	c/scp mix	wsbk/m	fr	.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .35
2	2-4% L	0-5"	cl	gr	vfr	.1942 WETNES CONDITION - S
		5"-39"	c	sbk	fi	.1943/.1956 SAPROLITE - 39" P.S.
		39"-48"	c/scp mix	wsbk/m	fr	.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
3	3-5% L	0-6"	cl	gr	vfr	.1942 WETNESS CONDITION - S
		6"-48"	c	sbk	fi	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946): SYSTEM TYPE Conventional, gravity fed.
EVALUATED BY: Michael J. Dennis OTHER(S) PRESENT: J.C. Moore.
COMMENTS:

DRAFT