HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____ ____
PROPERTY RECORDED: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Clyde Hall Enter, Inc. OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 8-16-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Perthwood S/D Lot # 12
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	3-5% L	0-7"	cl	gr	vfr	.1942 WETNES CONDITION	S
		7"-40"	c	sbk	fi	.1943/.1956 SAPROLITE	40" P.S.
		40"-45"	c/sap mix	sbk/m	fi	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
2	4-6% L	0-2"	cl	gr	vfr	.1942 WETNES CONDITION	S
		2"-42"	c	sbk	fr	.1943/.1956 SAPROLITE	42" P.S.
		42"-48"	c/sap mix	wsbk/m	fr	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	3-5% L	0-3"	cl	gr	vfr	.1942 WETNESS CONDITION	S
		3"-37"	c	sbk	fr	.1943/.1956 SAPROLITE	37" P.S.
		37"-45"	c/sap mix	wsbk/m	fr	.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE conventional, gravity fed.
EVALUATED BY: Michael W. Lennon OTHER(S) PRESENT: J.C. Moore
COMMENTS:

DRAFT

0 0 0 9 1 1