375.00 Paid

2:15

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 129546 PIN# 4730 70 5378.023 / 4730 70 0054 DATE October 17 2006

OWNER OR APPLICANT BD of N.C. Inc. / HERITAGE HOMES PHONE: Business _____ Home _____

ADDRESS 249 Williamson Rd, Mooresville, N.C. 28117

LOCATION Peeler Rd. (N) across from Clontz Hill Tr Winding Forest Dr. on Right before get to Winding Shore Dr.

SUBDIVISION Winding Forest BLOCK / SECTION _____ LOT 23 LOT AREA .824 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 794 Date _____

Pump Tank: 1000 Gallons; PT 318 Date 10/20/06

Pump Make: Little Giant Model EZ-1-HEN Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1065 Linear Feet 355

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 1 PPPBPS

Repair System Description: 1 PPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons 4

☐ Business No. Employees _____

☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

* Per Plan Specs

Comments:/Conditions:

Drainlines Checked 9/12/07 A. C.

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Diane Kozlowski date 10-18-06 Installed by: Piedmont Septic

Improvement Permit by: _____ date 10-17-06 Operation Permit by: Wesley Sparkes date 8/12/08

Authorization to Construct by: Wesley Sparkes date 12/19/06 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK