4730700895

IREDELL COUNTY HEALTH DEPARTMENT

STAT

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUC

PERMIT# 075666 PIN# 4730 60 9884

OWNER OR CONTRACTOR KIM L HYMAN

ADDRESS 19806 E ONE NORMAN CIR, CORNELIUS NC 2803

LOCATION Shady Cove Rd, South N TO Shady Cove on (L) P

SUBDIVISION Shady Cove BLOCK / SECTION 3 LOT 39 + 40 LOT AREA ~

Septic Tank: 1000 Gallons STB Date

Pump Tank: 750/1000 Gallons PT Date

Pump Make: Goulds Model WE05111N Serial No. 9941511

Nitrification Field No Fields 1 Square Feet 600 Linear Feet 200

No Lines *3 Trench Width 36" Max Trench Bottom Depth 36"

X New System

System Description:


Repair System Descr

Maintenance Agreem

Gravel Depth

Comments/Conditions: * 50% reduction NO GRADING IN DRAINFIELD OR REPAIR AREA

INITIAL SITE SKETCH (1" = 50')



I understand that this permit can be suspended or revoked if any false information is supplied toward securing tion of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan val to exceed sixty months.

Signed: * Kim L Hyman date 9/17/98

Improvement Permit by: Wesley Sparks R.S. date 9/14/98

Authorization to Construct by: Wesley Sparks R.S. date 9/14/98

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FI