IREDELL COUNTY HEALTH DEPARTMENT 4730704813

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tony Murdock DATE 4-22-83 PERMIT NO. 103

PHONE: Business _____ Home _____

LOCATION 150W TR 1303 TL 1439 0.4mile on left

S. R. No. _____

SUBDIVISION NAME Shady Cove LOT NO. 36 SECTION OR BLOCK NO. II


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	.5 GAL/ft²/day
Auto. Wash. Machine	Yes (X)	No ( )	Topography	10-15%
Site Suitable	Yes (X)	No ( )	Depth to Water Table	44
			Rock or other impervious formations	NONE observed

Lot Area 30,000ft²

_____ Basement with Plumbing X Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Wayne Atkinson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F. Clemmer

COMMENTS: No plumbing in 1 Basement

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 4-22-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold