IREDELL COUNTY HEALTH DEPARTMENT

4730-70-7313

STATESVILLE 70[illegible]305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 129600 PIN# 4730705378.032 DATE 10-23-07

OWNER OR APPLICANT Anaheim Homes

ADDRESS P.O. Box 610 Cornelius, NC 28031 PHONE: Business 704 896-3200 Home

LOCATION Perth Rd TL Winding Shore TR 1st road to right lot on left

SUBDIVISION Winding Forest BLOCK / SECTION LOT 32 LOT AREA .875 SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB $25 Date 6-10

Pump Tank: 1000 Gallons; PT $02 Date 6-10

Pump Make: ZOELLER Model M152 Serial No.

Nitrification Field: No Fields 1 Square Feet Linear Feet 320'

No Lines 4 Trench Width 24" min Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Pump-LP-Panel Block

Repair System Description: Same

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: See attached Septic System Design Plan by Michael Athanas & Assoc.

Comments:/Conditions: Replaces previous permit dated 10/11/06.

INITIAL SITE SKETCH

Revised Septic Design plan by Michael Athanas & Assoc. approved.

* No changes allowed without approval from I.C.H.D.

AS BUILT SKETCH

Set 2' Pressure Head

74' Panels Installed

Electrical Inspected 10-1-10 (No Septic Alarm Label)

Rechecked 10-6 Pass

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 11/6/07

Improvement Permit by: Maria H. Dotson RS date 10/23/07

Authorization to Construct by: Maria H. Dotson RS date 10/23/07

Installed by: Rowan Septic Tank

Operation Permit by: [signature] REHS date 6-6-10

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK