DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anaheim Homes
ADDRESS: ____
PROPOSED FACILITY: 4 bedroom PROPOSED DESIGN FLOW (.1949): 480gpd
LOCATION OF SITE: Winding Forest 3-2
WATER SUPPLY: • Private • Public X Well • Spring • Other ____
EVALUATION METHOD: X Auger Boring • Pit • Cut

APPLICATION DATE ____
DATE EVALUATED: ____
PROPERTY SIZE: ____
PROPERTY RECORDED: ____
TYPE OF WASTEWATER: X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3-5%	0-8	Br sc/ wsbk	Frsssp	F-4B's chr.2@45"	45"	—	—	PS 0.25 — 0.225
		8-32	Rsc/sc wsbk	Frsssp					
		32-45	Rsc wsbk	Frsssp					
2	5-7%	0-6	Br sc/ wsbk	Frsssp	mn.@28" 4B's@37" chr.2 @44"	44"	—	—	PS 0.25 — 0.225
		6-44	Rsc/sc wsbk	Frsssp					
3	5-7%	0-22	RBr scl wsbk	Frsssp	—	48"	—	—	PS 0.3
		22-48	Rc/cl sbk	Frsssp					
4	5-7%	0-7	RBr sc/ wsbk	Frsssp	—	48"	—	—	PS 0.3
		7-31	Rc sbk	Frsssp					
		31-42	Rcl wsbk	Frsssp					
		42-48	Rscl wsbk	Frsssp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	640 ft2	710 ft2
System Type(s)	PPBPS	PPBPS
Site LTAR	0.25	0.225

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: GM - MA
OTHER(S) PRESENT: ____

COMMENTS: ____