IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eugene Hedrick DATE 4-3-86 PERMIT NO. 134

PHONE: Business _____ Home _____


LOCATION 150W TR on Perth Rd TL on road before bridge before Skippers Landing 9th house on Right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other repair

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil clay
Percolation Rate 0.5 gal/ft²/day
Topography 2-10%
Depth to Water Table 4'
Rock or other impervious formations none obs.



Plot of System

existing tank
Size of Tank 1000 pump Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
minimum
(to close to lake)
Installed by doing away with
Donald Lackey

IMPROVEMENTS PERMIT BY Charles K Barnett

COMMENTS: replacing old system by pumping to adjoining lot with 1000 gal pump tank with alarm system to warn him when pump not working

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold