4730 71 9081

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jeff Hall DATE 8-4-87 PERMIT NO.

PHONE: Business Home

LOCATION 1303 N. TL in Shady Cove, round curve TL first St. ~300 ft. on left. 121 Alfara Ln S. R. No.

SUBDIVISION NAME Shady Cove LOT NO. 26 SECTION OR BLOCK NO. 2

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20000ft² ±

Character & Porosity of Soil Clay transition to P.M.
Percolation Rate ~4 gpd/ft²
Topography 4-8%
Depth to Water Table 4'+
Rock or other impervious formations none observed

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12'
Water Supply: Individual (✓)
Public ( )

Installed by Smith Builders

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH, ACP

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew C. Price

EXISTING SYSTEM CHECKED BY: D. R. Hanson, RS. DATE 8-4-87

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold