IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Hayes DATE 2 Oct 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1 mi S. of Troutman on Rural S. Rd to Rd # 1318. 4th gate ¼ mi - House on Right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate none
Topography Slope & Rolling
Depth to Water Table ok
Rock or other impervious formations ok

Lot Area 7½' X 100'



Plot of System Rd # 1318

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Tom Howard DATE 2 Oct 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold