IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Hayes DATE 2/24/11 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1 mi S of Troutman on Post Oak Rd to Rd # 1318. 1st house on R ~ House on Right

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2 ½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate none
Topography Slope & Level
Depth to Water Table nl
Rock or other impervious formations nl

Lot Area 7½' X 100'



Plot of System 1318

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

E-MAILED Approved 3/29/11 DB Jones

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Tim Howard

IREDELL COUNTY HEALTH DEPT.
ENVIRONMENTAL DIVISION
318 TURNERSBURG HIGHWAY
STATESVILLE, NC 28625

DATE 2/24/11

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

The location of the proposed garage addition addition does not appear to impact the existing septic system.

**NOTE: _____

REHS

Date: 3-29-11
ICHD-Environmental Health Division

s Copy: Pink Owner's Copy: Gold