REDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 12947 PIN# 4730 70 5378.003 4730-80-4025 DATE October 19, 2006

OWNER OR APPLICANT BD of N.C. Inc PHONE: Business Home

ADDRESS 249 Williamson Rd, Mooresville, NC 28117

LOCATION Peeth Rd (N) TL across from Clontz Hill Rd onto Winding Forest Dr. 3rd lot on left

SUBDIVISION Winding Forest BLOCK / SECTION LOT 3 LOT AREA 1.035 Ac SITE CLASS PS DESIGN FLOW 460gpd L.T.A.R. .225

1 HP

Septic Tank: 1000 Gallons; STB 786 Date 3/13/07

Pump Tank: 1000 Gallons; PT 32 Date 12/10/07

Pump Make: Zoeller Model 139 Serial No.

Application Field: No Fields 1 Square Feet 1080± Linear Feet 360

No. Lines 4 Trench Width 36" ± Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☒ Public ☒ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

☒ PER plan specs

Comments:/Conditions:

INITIAL SITE SKETCH

SEE Plan from Rollins Soil and Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Diane Rollins date 10-30-06 Installed by: C+M Contracting

Improvement Permit by: date 10-19-06 Operation Permit by: Judy Melville date 12-6-07

Authorization to Construct by: date 1/10/07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK