IREDELL COUNTY HEALTH DEPARTMENT 4730 81 2273

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Hope DATE 8-22-83 PERMIT NO. 290

PHONE: Business _____ Home _____

LOCATION 150 W. TR 1303. About ¼ mile on left before Skipper's Landing S. R. No. _____

SUBDIVISION NAME Shady Cove LOT NO. 7 SECTION OR BLOCK NO. II


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Loamy Quartz sands
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0-6 gal/ft²/day
Auto. Wash. Machine	Yes (X)	No ( )	Topography	4%
Site Suitable	Yes (X)	No ( )	Depth to Water Table	
			Rock or other impervious formations	NONE observed

Lot Area 20,000 Ft²

~~Basement with Plumbing~~ Basement without Plumbing ___ X ___ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Steve Dameron

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY David Hinson

COMMENTS: upper line too deep, lower line about 1.5' cover

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 8-22-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold