DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Thell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Darin + Andrea Jones APPLICANT: _____
ADDRESS: PO Box 853 Troutman, NC 28166 APPLICATION DATE: 6-15-2000 DATE EVALUATED: _____
PROPOSED FACILITY: 4 Bdrm House PROPOSED DESIGN FLOW (gpd): 450 PROPERTY SIZE: 1 July 5 2000
LOCATION OF SITE: Hwy 21 SB Rt (3) Rt (2) Rt immediately on Rt past 1st house on Rt PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8-10%	0-3	SCL						PS -.3 plus
		3-20	SAB CL	FR					
		20-24	SAB C w/ SAP	FR					
		24-36	SAB C w/ SAP	FR VFR					
		36-48	SAP w/clay	VFR					
2	L 2-3%	0-10	SCL						PS -.3
		10-36	SAB C	FR					
		36-52	SAB C w/ SAP	FR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	✓	✓
System Type(s)	25% Red	Rep 25%
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: C Pettak
OTHER(S) PRESENT: _____