IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 162784 PIN # 4730 92 5095 DATE

OWNER or APPLICANT Cynthia & Erin Lacoille PHONE: Business Home: 704-746-5378

OWNER or APPLICANT ADDRESS 468 Clontz Hill Rd Troutman 28166

LOCATION / DIRECTIONS Hwy 21 N TL Flowerhouse TL Clontz Hill TR Hamptons Cove at corner

SUBDIVISION Clontz Property BLOCK / SECTION LOT # 1 LOT AREA 1.113 Ac DESIGN FLOW 360gpd L.T.A.R. .3 gpd/ft2

Septic Tank 1000 Gallons: STB 786 Date 6-10-10

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 2 Linear Feet 300

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% reduction gravity

Repair System Description: 25% reduction gravity

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3 ☐ Business No. Persons 6 ☐ Other No. Employees ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

Share Berm in system area
May center feed system

Comments / Conditions Blue Fitter installed
Drainfield = 306 ft Quick 4 installed
8/27/2010

INITIAL SITE SKETCH

See Plan from
Rollins Soil &
Environmental Services
Approved by ICHD

AS BUILT SKETCH

See Redraw (As Built)
Issued 8/31/2010

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 8/30/10

Improvement Permit by: Judy Melville Date 8-9-10

Authorization to Construct by: Judy Melville Date 8-9-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: S & L Grading

Operation Permit by: Date:

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant