12752.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR EDWIN MURDOCK DATE 5-6-91. PERMIT NO. 3K-A-9.

PHONE: Business _____ Home _____

LOCATION East Monbo Rd. off Old Mty. Rd. - go approx. 1.5 miles on left - mobile home behind green house.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms / No. Bathrooms / Character & Porosity of Soil Prov. Suitable.

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 2-6 MPI 49 ft.


Auto. Dishwasher Yes ( ) No (✓) Topography 2-6%

Auto. Wash. Machine Yes ( ) No (✓) Depth to Water Table 18+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations none observed.

Lot Area 12.7 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Esker Elder

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-6-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold