Site Address: 141 Talley Ridge Dr. Iron. (CI)

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# TROUTMAN 137 895 PIN# 4731-22-5803.10 4371 DATE 08/30/06

OWNER OR APPLICANT MEDALLION PROPERTIES, INC. PHONE: Business 704-634-1185 Home 704-361-1084

ADDRESS 185 WHIPPERWILL RD, MOORESVILLE, NC 28117

LOCATION HWY 21 SOUTH (R) TALLEY ST., (L) TALLEY HILLS DR. LOT @ END ON CUL-DE-SAC.

SUBDIVISION TALLEY RIDGE BLOCK / SECTION ____ LOT 10 LOT AREA 0.50 ACRES SITE CLASS. PS DESIGN FLOW 360 GPD L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1,000 Gallons; STB 825 Date 8-22-06

Pump Tank: 1,000 Gallons; PT 307 Date 10-02-06

Pump Make: Zoeller Model N1523 Serial No. ____

Nitrification Field: No Fields 1 Square Feet EQ to 1,200 Linear Feet 200'

No Lines 4 Trench Width 24" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 50% REDUCTION, LOW PRESSURE

Repair System Description: 50% REDUC, L. PRESSURE

Maintenance Agreement Required: ☒ Yes ☐ No

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other


No. Bedrooms 3 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual WELL ☐ Public ☐ Community

Comments:/Conditions: (1) SUPPLY LINE MUST BE INSTALLED AS SHOWN TO AVOID DAMAGE TO REPAIR AREA, (2) SEE ATTACHED PUMP AND LOW PRESSURE PANEL DIAGRAMS.

Comments:/Conditions:

INITIAL SITE SKETCH



* NOT TO SCALE ~1"=50'

* LINES

(1) 2'X30' – USE 7 PANELS
(2) 2'X60' – USE 14 PANELS
(3) 2'X50' – USE 11 PANELS
(4) 2'X60' – USE 14 PANELS

AS BUILT SKETCH

LL 4'x 12-4-06


Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Phil Campagna date 8/30/06 Installed by: Rowan Septic

Improvement Permit by: [signature] date 08/29/06 Operation Permit by: [signature] date 12-7-06

Authorization to Construct by: [signature] date 08/30/06 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK


59.27'
241.52'
25.00
RELOCATED DRIVEWAY EASEMENT
241.42'
65.09'
S 39°12'03" E
272.37'TOT.
148.52'TOT.
S 09°13'04" W
253.17'TO
EX.1/2" PIPE
110.57'
S 64°32'33" W
S 80°13'51" E
160.25'TOT.
S 48°58'59" E
78.67'
C7
C6
C8
C5
S 83°04'46" W
70.40'
N 80°13'51"
C9
C4
C3
C10
1.91'
LAYOUT BY ASHLEY ROLL
103.43'
S 80°13'51" E
237.23'
67.30'
LINES NOT LAYED OUT IN FIELD AREA SHOULD BE SUFFICIENT FOR SBR
100.00'
N 80°13'51" W
240.71'
EX.1/2" PIPE EAST OF LINE 0.42'
33.74'
S 80°13'51" E
227.83'
100.44'
LINES NOT LAYED OUT IN FIELD AREA SHOULD BE SUFFICIENT FOR SBR
100.00'
231.26'
S 80°13'51" E
218.43'
20.00'
PSDE
N 80°13'51" W
15' SETBACK
40' SETBACK (TYP)
EX.#4 REBAR WEST ON LINE 0.52'
87.33'
102.00'
S 09°46'09" W
101.00'
15' SETBACK
S 80°13'51" E
208.85'
15' SETBACK (TYP)
N 80°13'51"
212.26'
N 09°46'09"
756.84'TOT.
107.00'
107.47'
N 09°46'09"
768.51'

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES

DIVISION OF ENVIRONMENTAL HEALTH

ON-SITE WASTEWATER SECTION

SHEET: 1 of 2
PERMIT #:
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER/APPLICANT: Medlin Prop
ADDRESS:
PROPOSED FACILITY: 3 BR SFD PROPOSED DESIGN FLOW (.1949): 360 GPD
LOCATION OF SITE: LOT #10 Talley Ridge S/D
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

APPLICATION DATE:
DATE EVALUATED: 8-29-06
PROPERTY SIZE: 0.50 Ac.
PROPERTY RECORDED:

PROFILE #	.1940 LSCP PSTN/ SLOPE %	HORIZ DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L/N	0-22	2/1, M, sbk, C	Fr, SP, SEXP	N/A	48"+	N/A	>48"	PS 0.30
		22-42	2/1, M, sbk, C W/ SAP. INCLUS.						
		42-48	1, M, sbk, CL + SAP MIX (<50% SAP)						
2	L/N	0-24	2/1, M, sbk, C	Fr, SP, SEXP	N/A	48"+	N/A	>48"	PS 0.30
		24-44	2/1, M, sbk, C W/ SAP. INCLUS.						
		44-48	1, M, sbk, CL + SAP MIX (<50% SAP)						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	600 FT²	600 FT²
System Type(s)	50% Reduc, L.P.	50% Reduc, L.P.
Site LTAR	0.30	0.30

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: P. Mitchell
OTHER(S) PRESENT:

COMMENTS:

(PAGE 2 ON REAR)

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION
CC (Concave Slope)
CV (Convex Slope)
D (Drainage Way)
DS (Debris Slump)
FP (Flood Plain)
FS (Foot Slope)
H (Head Slope)
L (Linear Slope)
N (Nose Slope)
R (Ridge)
S (Shoulder Slope)
T (Terrace)

GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*
I	S (Sand) LS (Loamy Sand)	1.2 - 0.8	0.6 - 0.4
II	SL (Sandy Loam) L (Loam)	0.8 - 0.6	0.4 - 0.3
III	Si (Silt) SiCL (Silty Clay Loam) CL (Clay Loam) SCL (Sandy Clay Loam) SiL (Silt Loam)	0.6 - 0.3	0.3 - 0.15
IV	C (Clay) SC (Sandy Clay) SiC (Silty Clay) O (Organic)	0.4 - 0.1 None	0.2 - 0.05 None

MINERALOGY/ CONSISTENCE
NEXP (Non-expansive)
SEXP (Slightly Expansive)
EXP (Expansive)

MOIST
VFR (Very Friable)
FR (Friable)
FI (Firm)
VFI (Very Firm)
EFI (Extremely Firm)

WET
NS (Non Sticky)
SS (Slightly Sticky)
MS (Mod. Sticky)
VS (Very Sticky)

NP (Non Plastic)
SP (Slightly Plastic)
MP (Mod. Plastic)
VP (Very Plastic)

STRUCTURE TYPE
G (Single Grain) [*Structureless*]
M (Massive) [*Structureless*]
CR (Crumb)
GR (Granular)
SBK (Subangular Blocky)
ABK (Angular Blocky)
PL (Platy)
PR (Prismatic)
COL (Columnar)
CMPD (Compound) [___ parting to ___]

STRUCTURE GRADE
0 (Strucutreless)
1 (Weak)
2 (Moderate)
3 (Strong)

STRUCTURE CLASS
VF (Very Fine)
F (Fine)
M (Medium)
C (Coarse)
VC (Very Coarse)


***Adjust LTAR due to depth, consistence, structure, soil wetness, landscape position, wastewater flow and quality.**

NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

*** Evaluation of saprolite shall be by pits.**
Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).



SOIL/SITE EVALUATION

(Continuation Sheet)

Sheet _____


DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH


LOT #10

PROPERTY ID #: _____
DATE OF EVALUATION: _____
COUNTY: _____

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 10	L/ 15-20	0-22	RC msbk	Fr SS P SEXP	comingsap incl.	44"	PS	N/A	PS-60 0.3
		22-44	RB cl wsbk	Fr SS SP SEXP					
		44-60	verig. "1" sap	Fr SS SP SEXP					
P 11	L/ 6-10	0-5	BO sl sr	Fr SS SP SEXP	few sap incl.	48"	N/A	N/A	PS-48 0.3
		5-34	RB c mAbk/sbk	Fr SS P SEXP					
		34-48	RB cl msbk	Fr SS SP SEXP					
P 12	R/ 0-5	0-5	B scl fwsbk	Fr SS SP SEXP	comm sap incl.	57"	N/A	N/A	PS-57 0.3
		5-31	RC msbk/Abk	Fr SS P SEXP					
		31-57	R cl wfsbk	Fr SS SP SEXP					
P 13	R/ 6-10	0-36	RC mAbk/sbk	F SS P SEXP	few-comm YB mtts vfew Sap incl comm sap incl.	48"	N/A	N/A	PS-48 0.275
		36-48	R scl mwsbk/Abk	F SS SP SEXP					
P 14	L/ 6-10	0-8	B scl wfsbk	Fr SS SP SEXP	comm Sap & Rock incl.	48"	N/A	N/A	PS-48 0.275
		8-38	RC msbk/Abk	Fr SS P SEXP					
		38-48	BR C l+sap fwsbk	Fr SS SP SEXP					

COMMENTS: ASHLEY ROLLANS


GERALD T. ADDLEY JR. &
MARY P. ADDLEY
1528/653
ZONED:R-20
RICHARD D. ROGERS
808/183
ZONED:R-20
RICHARD D. ROGERS
749/838
ZONED:R-20
H. MAX OSTWALT
754/923
ZONED:R-20
TALLEY HILLS DRIVE
PUBLIC R/W
EX. REBAR
EX. PAVEMENT
CONCRETE CONTROL MONUMENT
BARBED WIRE FENCE ENCROACHMENT
Must Remove Fill
2020.50 TALLEY



Pressure Dosed PPBPS


of panels 46/11.
Size holes 5/32. 1 hole per panel.
Approximate amount of sand needed 33 1/4 TONS
100 lbs. of partical sand per 8 panels.
Sidewalls raked and limed.
GPM 19.
TDH ~12'.

Comments

PUMP TANK DESIGN

ATTACHMENT TO PROPERTY DESCRIPTION # _____

TAX MAP # 4731-22-5803.10



1) APPROXIMATE PUMP CYCLE
   TIE DOWN "A" - 4" 6" 8" 10" 12" 14" 16"
   DIFFERENTIAL "B" - 10" 12" 14" 17" 20" 24" 28"

2) SIZE WIRE TO PUMP FOR TOTAL RUN FROM HOUSE PANEL TO PUMP

3) PROVIDE SEPARATE CIRCUIT BREAKERS FOR PUMP POWER & IN-HOUSE PANEL

4) SEALED MERCURY CONTROL FLOATS ATTACHED TO 2½" SCHEDULE 40 PVC PIPE SLIPPED OVER 2" SCHEDULE 40 PVC PIPE ANCHORED IN CONCRETE

5) USE PUMP SIZED TO DELIVER 19 GPM AT 12' TDH

IREDELL COUNTY HEALTH DEPARTMENT

Application For Improvement Permit and/or Authorization To Construct, Existing System Inspection

(THE ABOVE PERMIT DOCUMENTS WILL BECOME INVALID IF INFORMATION PROVIDED ON THIS APPLICATION IS FALSIFIED OR CHANGED, OR IF THE SITE IS ALTERED. THE IMPROVEMENT PERMIT IS VALID FOR EITHER 60 MONTHS OR WITHOUT EXPIRATION DEPENDING UPON DOCUMENTATION SUBMITTED - APPLICATION WITH SITE PLAN 60 MONTHS, APPLICATION WITH COMPLETE, SCALED PLAT WITHOUT EXPIRATION. SEE 15A NCAC 18A .1937(f) FOR DETAILS)

1. APPLICATION FOR: ___ Improvement Permit ___Authorization To Construct ✓ BOTH ___Existing System Inspection

2. Page 2: *Site Plan Worksheet* Form MUST Accompany This Application
   The following optional attachments may also be submitted: ✓ Survey Plat, Scaled no more than 1 Inch = 60 Feet
   Place check ( ) beside whichever is submitted if applicable ___ Custom Site Plan, Scaled no more than 1 Inch = 60 Feet

3. **Applicant Information:**

Medallion Properties, Inc.	185 Whippoorwill Rd Mooresville NC 28117	704 634	1185
Applicant Name	Mailing Address	Home Phone	Work Phone
Ryan-West Dev.	215 Crystal Circle Mooresville 28117	704	361 1084
Owner Name	Mailing Address	Home Phone	Work Phone

4. **Property Information:**

	Talley Ridge	Lot 10
Street Address	Subdivision Name	Section/Phase and Lot Number

Driving Directions: Hwy 21 N, (L) Talley Rd, (L) Talley Hills Drive

****

5. **RESIDENTIAL Site Development Information:** *(Check or Complete ALL that apply)*

(✓) New, Single Family Residence
( ) New, Multi-Family Residence
( ) Expansion of Existing Septic System
( ) Repair To Failing Septic System

Maximum Number of Bedrooms 3
Maximum Number of Occupants ___
If Expansion, Current Number of Bedrooms ___

(✓) Crawl Space Foundation?
( ) Concrete Slab Foundation?
( ) Basement w/Plumbing?
( ) Basement w/out Plumbing?

IF Non- Residential Site Development:
Type of Business ___
Square Footage of Building ___
Maximum Number of Employees ___
Maximum Number of Seats ___

****

6. **Proposed Water Supply:**

(✓) New Well ( ) Existing Well ( ) Community Well ( ) City Water ( ) Other Public Water

****

7. **Desired Septic System Type:** *(You may rank in order of preference, if any)*

( ) Alternative ( ) Conventional ( ) Innovative ( ) Modified Conventional ( ) Other___ (✓) No Preference

****

8. **Please Answer The Following To The Best of Your Ability:**

( ) Yes (✓) No Does the site contain any jurisdictional wetlands?
( ) Yes (✓) No Is any non-domestic sewage (i.e. industry) to be generated?
( ) Yes (✓) No Is the site subject to approval by any other public agency?

****

I have read this application and certify that the information provided herein is true, complete, and correct. Authorized county and state officials are granted right of entry to conduct necessary inspections to determine compliance with applicable laws and rules. I understand that I am solely responsible for the proper identification and labeling of all property lines and corners and making the site accessible so that a complete site evaluation can be performed.

9. Signature: Medallion Properties Inc. — 6/15/06
   Property owner or owner's legal representative signature (SIGNATURE REQUIRED) — DATE
   By: Gilbert Campagna, President

IREDELL COUNTY HEATLH DEPARTMENT

PAGE 2: *SITE PLAN WORKSHEET*

SEE THE SAMPLE SITE PLAN BELOW. INCOMPLETE SITE PLANS WILL BE RETURNED TO YOU FOR COMPLETION AND MAY RESULT IN A DELAY IN THE ISSUANCE OF YOUR SEPTIC SYSTEM PERMIT!!!

Place an (X) beside each item as you complete the site plan:

____ Property Line measurements are clearly identified…
____ All proposed structures are indicated…
____ *SHOW: proposed house or business footprint, wells, water lines, patios, pools and decks, and any other item that will occupy space on the site*
____ Front and side setbacks from property line…
____ Preferred driveway location and configuration, preferred well location…
____ Area you prefer your septic system to be placed…
____ North arrow, or other sufficient indicator of direction…


Circle N/A on the following if appropriate:

____ Location of septic systems and wells within 100' of your property… N/A
____ Location of easements and rights of ways on your property… N/A
____ Location of any designated wetlands on the property… N/A


Signature: Medallion Properties, Inc 6/15/06
Property owner or owner's legal representative signature (SIGNATURE REQUIRED) **DATE**
By: Gilbert P. Campagna, President

USE THIS SPACE TO DRAW YOUR SITE PLAN

* See Attached



Forsythe


N 75°04'24" W
241.52'
590.80'TOT.
25.00
RELOCATED DRIVEWAY
EASEMENT DB 1591 PG 1703
241.42'
25' REAR SETBACK
10
21,898SQ.FT.
0.50AC.
10'x10' Deck
S 39°12'03" E
272.37'
148.52'
S 09°13'04" W
25' REAR SETBACK
9
22,085 SQ.FT.
0.51 AC.
253.17'
15' SETBACK
S 64°32'33" W
11
26,956 SQ.FT.
0.62 AC.
145' SETBACK
67' SETBACK
57' SETBACK
102' SETBACK
S 48°58'59" E
78.67'
S 80°13'51" E
160.25'
C7
C6
C8
C5
12
21,988 SQ.FT.
0.50 AC.
66' SETBACK
S 80°13'51" E
118.13'
24" RCP
24" RCP
C9
C4
11' SEPTIC EASEMENT
S 15°10'09" W
80.14'
C10
C3
1.91'
34.81'
S 80°13'51" E
237.23'
13
23,253 SQ.FT.
0.53 AC.
100.00'
18" RCP
11' SEPTIC EASEMENT
100.00'
7
42,650 SQ.FT.
0.98 AC.
67.30'
33.14'
S 80°13'51" E
227.83'
N 80°13'51" W
231.26'
14
22,313 SQ.FT.
0.51 AC.
100.44'
100.00'
6
22,653 SQ.FT.
0.52 AC.
S 80°13'51" E
218.43'
18" RCP
18" RCP
15.12'
20' STORM DRAINAGE
EASEMENT
20.00'
PSDE
N 80°13'51" W
221.8
15' SETBACK (TYP)
15
21,791 SQ.FT.
0.50 AC.
87.33'
102.00'
40' SETBA
5


Patrick

FRANK BETZ ASSOCIATES, INC.

HOMEPLANS *Designed for Today's Market.*

Lot 10 Talley Ridge

FORSYTHE - Main Floor



FLOOR PLAN

Floorplans and Elevations are subject to change. Floorplan dimensions are approximate. Consult working drawings for actual dimensions and information. Elevations are artists' conceptions.

Acknowledgement Of
Plans Submittal ONLY!
Date 08/30/06
Date 8/30/06

http://www.frankbetz.com/homeplans/printer_friendly.html?pn=3686&vw=3 6/15/2006

Aug 30 06 07:54a Will Campagna 7047992710 p.3

TOWN OF TROUTMAN
ZONING CLEARANCE APPLICATION
PERK TEST ONLY

PAID
JUN 15 2006
TOWN OF TROUTMAN

Change of Principal Use
New or Enlarged Principal Use — *XX*
New or Enlarged Accessory Structure

PERMIT 05 -p- 06-06 ***DATE OF APPLICATION*** 06/15/06

APPLICANT'S NAME Medallion Properties, Inc.
APPLICANT'S MAILING ADDRESS 185 Whippoorwill Rd.
Mooresville, NC 28117

DAY TIME PHONE # (704) 634-1185

PROPERTY LOCATION: Talley Ridge Subdivision, Lot 10

TAX MAP OR PARCEL IDENTIFICATION NUMBER (PIN): 4731225803.10

EXISTING ZONING: R-20 ***IN A SPECIAL FLOOD HAZARD AREA?*** ***Yes*** ____ ***No*** X

LOT DIMENSIONS: ***(Fill in all four blanks)*** ***Length*** 148'/272' ***Area*** 21898 sq. ft
Width 38'/241' ***Street Frontage*** 38'

TYPE OF BUILDING PROPOSED AND/OR PROPOSED USE: Residential – Single Family

PROPERTY OWNER'S NAME: Ryon-West Developers, LLC

PROPERTY OWNER'S MAILING ADDRESS 215 Crystal Circle, Mooresville, NC 28117

RELATIONSHIP OF APPLICANTS TO PROPERTY OWNER Buyer

IF ACCESSORY STRUCTURE, CHECK PROPOSED YARD LOCATION

Front: ____ ***Right Side:*** ____
Rear: ____ ***Left Side:*** ____

STRUCTURE REQUIREMENT *(Note: A separate application must be completed for each structure)*

(Set Backs)	***Required***	***Proposed***
Lot Area	20000	21898
Side Yard—Left	15'	15'
Side Yard—Right	15'	15'
Front Setback(from road R/W)	40'	67'
Building Height	35' Max	
Lot Width at Building Line	100'	100'
Rear Yard Setback	25'	25'

****Additional ten feet (10') required on all side yards which abut a public or private street***

Comments: **PERK TEST ONLY!!!! No Water or sewer available**

ATTACHMENTS

In order to be considered complete, the following must accompany each application:

1. A fee (in cash or a check made payable to the Town of Troutman) in the amount of $25.00 shall be submitted to the Zoning Administrator.
2. A scaled dimensional drawing which shows (a) the exact shape, dimensions and location of the lot to be built upon, and (b) the exact shape, dimensions, use and location of existing structures on the lot. Upon this survey or drawing shall be sketched the following: (a) the exact shape, dimensions and area of the structure(s) to be placed upon the lot; (b) all setback lines on the lot once the proposed structure is completed; and (c) any other information that may be needed to insure that the proposed structure is in compliance with all applicable provisions of the Ordinance

CERTIFICATION

1. I hereby certify that all of the information provided for this application is, to the best of my knowledge, accurate and complete.

Medallion Properties, Inc.
By: Robert P. Compagni, President — Date: 6/15/06
Signature of Applicant

2. I, Ryan-West Develop, Owner of property 4731225803.10 (list PIN number) in Troutman, North Carolina, do hereby authorize Medallion Properties (Applicant's Name) to submit this zoning permit application to the Zoning Administrator on my behalf.

Date: 6/14/06
Signature of Property Owner

3. To the best of my knowledge, this application is accepted and deemed complete.

John B. Garland — Date: 6-21-06
~~Donald E. Duncan, Jr.~~ JOHN B. GARLAND
Signature of Zoning Administrator

(THE FOLLOWING SHALL BE FILLED OUT BY THE ZONING ADMINISTRATOR)

Based on the information hereby furnished to me and my knowledge of the Troutman Zoning Ordinance, I hereby: X **APPROVE** ____ **DISAPPROVE** this Zoning Permit.

TOWN OF TROUTMAN, INC. ZONING OFFICER

COMMENTS: _____

John B. Garland — Date: 6-21-06
~~Donald E. Duncan, Jr.~~ JOHN B. GARLAND
Zoning Administrator

THIS PERMIT EXPIRES SIX (6) MONTHS FROM THE ISSUE DATE.