IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dale Rogers DATE 6/22/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S To Troutman - T.R. at B-t-H Amoco on Rd # 1424 Pass Rd # 1423. House on L. Back off of Road S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope Low
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	None

Lot Area 5 Acres



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hicks Septic Tank Co.

Rd 1424

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/22/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold