IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 8/20/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. to Troutman, T.R. at Tally House Rest on Rt 1324 T.L. on 1323, T.R. at end of Street 1st on Lt. S. R. No. _____


SUBDIVISION NAME Cardell Acres LOT NO. 20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev Suitable	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Road	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low	
			Rock or other impervious formations	None	

Lot Area 20,000 Sq ft



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Hope Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts and all surface water possible to be diverted away from Septic Tank + line.

CERTIFICATE OF COMPLETION BY E. C. Stevenson DATE 8/20/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold