IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# REPAIR PIN# 4731317567 DATE 3-7-08

OWNER OR APPLICANT CARL & BRENDA GILBERT PHONE: Business Home 704-528-9134

ADDRESS 177 LYTTON FARM RD TROUTMAN, N.C. 28166

LOCATION 21 SOUTH (R) [redacted] TALLEY RD (L) LYTTON FARM ON LEFT AT BOX # 177

SUBDIVISION BLOCK / SECTION LOT LOT AREA SITE CLASS. DESIGN FLOW L.T.A.R.

Septic Tank: 1000 Gallons; STB 794 Date 10-8-07

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet EQ=120 Linear Feet 300

No Lines 5x60' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☐ Pressure

☑ New System ☒ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: GRAVITY 25% REDUCT

Repair System Description:

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 6 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: (1) LINES HAVE MAX. 12" FALL. START TRENCH BOTTOM AT 24" DEEP AT SHALLOWEST PT SO DEEPEST PT WILL BE 36", (2) LAST 2 LINS ARE 9' ON CENTER

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LOWE CODY, P.S.

Comments/Conditions: FOR SCALE LIMITATIONS [redacted] (3) INSTALL NEW [redacted] (4) TREES ARE RECOMMENDED TO BE REMOVED (5) OLD SYSTEM WILL BE ABANDONED (6) SYSTEM AS-BUILT SKETCH MUST BE 10' OFF P/L'S

DESCONNECTED

(X) THIS PERMIT SERVES AS NOTICE OF VIOLATION AND MUST BE REMEDIED WITHIN 30 DAYS.

DOUBLE LOW FLOW MAYBE

Line length 60. = 1

60 = 2

60 = 3

60 = 4

60 = 5

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made to the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to the Improvement Permit – not to exceed sixty months.

Signed: Carl L. Gilbert Jr. date 3-10-08 Installed by: A-1 BACKHOE 290

Improvement Permit by: date 3-7-08 Operation Permit by: date 3-10-08

Authorization to Construct by: date 3-7-08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

4713131756
383
383
150
87
182
125
LYTTON FARM RD
S. BEND
95
DEN LON LN
87
29
158
66
191
125
Shed
Existing Home
Old Tank
Old System
185
NEW TANK
40
40
282
E
S
W
N
WELL
100'
100'
Driveway
Carport
4'
4'
8'
5'
8'
5'
8'
5'
Ski