IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ROBERT JONES DATE 1-31-84 PERMIT NO.

PHONE: Business Home

LOCATION 21 south, T.R. on Old Mtn. Rd., T.L. on East Monbo Rd., go to Parkwood Acres, T.R. into dev. - 2nd gravel drive on left - 1st house on (R).

SUBDIVISION NAME S. R. No.

LOT NO. 57A SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2 acres +

Character & Porosity of Soil Prev. Suitable
Percolation Rate 5 gal/sq. ft.
Topography 2-6%
Depth to Water Table 12+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Brim
I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Terry L. Pierce

COMMENTS: Landscape over S.T. system for surface water control.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 1-31-84.
EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold